



Italia

Certificato IS-272293-01-18
31/01/2018

Scegli la certezza.
Aggiungi valore.

FIRE SAFE TEST CERTIFICATE

Valve Type: **AP64 SOFT SEATED BALL VALVE SIZE DN 2" CLASS 150 RF**
To Drawing N° **L92000-DPL rev.0**
Date **nov-17**

CERTIFICATE NUMBER: **IS-272293-01-18**

CLIENT: **PENTA S.r.l.**
ADDRESS: **VIA BOCCACCIO, 23**
25080 MOLINETTO DI MAZZANO (BS)

REPORT NUMBER: **N° 11/01/2018 L92000-DPL**

SCOPE OF REPORT: **Fire Safe test carried out according to Client procedure**

BS - UNI EN ISO 10497:2010
API STANDARD 607 Seventh Edition, June 2016

max bar: **2,1**

max °C: **832**

TÜV
INSPECTOR

PAOLO POZZI



TÜV ITALIA S.R.L.
TÜV SÜD Group

Direzione e Sede Amministrativa:
Via Giosué Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Sede legale: Via Mauro Macchi, 27 20124 Milano
Società soggetta al controllo e al coordinamento di
TÜV SÜD AG

Telefono: +39 02 24130.1
Telefax: +39 02 24130.399

www.tuv.it

CERTIFICATION DATE

31/01/2018

MANAGEMENT OF
INSPECTION SERVICE

VITTORIO FEDERICI



Registro delle Imprese di Milano
n. iscrizione e Cod. Fisc. 08922920155
R.E.A. 1255140 - P. IVA 02055510966
Capitale sociale : Euro 500.000 int. vers.
Coord. Bancarie: INTESA BC1 - CIN J
c/c 000018978166 - ABI 03069 - CAB 32934
IBAN: IT34 J030 6932 9340 0001 8978 166



Italia

FIRE SAFE TECHNICAL REPORT

FIRE SAFE CERTIFICATE N°: IS-272293-01-18

REPORT N°: N° 11/01/2018 L92000-DPL

CLIENT: PENTA S.r.l.

ADDRESS: VIA BOCCACCIO, 23 - 25080 MOLINETTO DI MAZZANO (BS)

QUALIFIED VALVE

<u>VALVE SIZE:</u>	2"
<u>VALVE RATING CLASS:</u>	150
<u>DRAWING N°:</u>	N° L92000-DPL
<u>VALVE TYPE:</u>	AP64 SOFT SEATED BALL VALVE SIZE DN 2" CLASS 150 RF
<u>MAX bar:</u>	2,1
<u>MAX °C:</u>	832

RANGE AND TYPE OF NPS: 2 and below; 2 ½; 3; 4 DN: 50 and below; 65; 80; 100 (ISO 10497 and API607)

VALVES COVERED: CLASS: 150; 300 - PN 10; 16; 25; 40 (ISO 10497 and API607)

THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:

API STANDARD 607 Seventh Edition, June 2016

BS - UNI EN ISO 10497:2010

NOTES:

LOCATION AND DATE OF TEST CARRIED OUT:

At CO.MA.IS. s.a.s – Via Marelli, 70 – 20043 Cerro Maggiore (MI) - 30/01/2018

TÜV
INSPECTOR

