



FIRE SAFE TEST CERTIFICATE

Valve Type: **BALL VALVE SIZE DN 8" FB SAT TRUNNION CLASS ANSI 150 RF**
To Drawing N° **N14200-DPL rev.0**
Date **30-nov-2020**

CERTIFICATE NUMBER: IS-272293-03-20

CLIENT: PENTA S.r.l.
ADDRESS: VIA BOCCACCIO, 23
25080 MOLINETTO DI MAZZANO (BS)

REPORT NUMBER: N° 01/12/2020 N14200-DPL

SCOPE OF REPORT: Fire Safe test carried out according to Client procedure
API SPECIFICATION 6FA Fifth Edition, January 2020
BS - UNI EN ISO 10497:2010
API STANDARD 607 Seventh Edition, June 2016

max bar: **15,9**

max °C: **883**



TUV ITALIA S.R.L.
TUV SUD Group

Direzione e Sede Amministrativa:
Via Giosuè Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Sede legale: Via Mauro Macchi, 27 20124 Milano
Società soggetta al controllo e al coordinamento di
TUV SUD AG

Telefono: +39 02 24130.1
Telefax: +39 02 24130.399

www.tuv.it

CERTIFICATION DATE

02/12/2020

MANAGEMENT OF
INSPECTION SERVICE



Registro delle imprese di Milano
n. iscrizione e Cod. Fisc. 08922920155
R.E.A. 1255140 - P. IVA 02055510966
Capitale sociale : Euro 500.000 int. vers.
Coord. Bancarie: INTESA BCI - CIN J
c/c 000018978166 - ABI 03069 - CAB 32934
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.
TÜV SÜD Group
Via Giosuè Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Telefono: +39 02 24130.1
Telefax: +39 02 24130.399
www.tuv.it



Italia

FIRE SAFE TECHNICAL REPORT

FIRE SAFE CERTIFICATE N°: IS-276165-03-20

REPORT N°: N° 01/12/2020 N14200-DPL

CLIENT: PENTA S.r.l.

ADDRESS: VIA BOCCACCIO, 23 - 25080 MOLINETTO DI MAZZANO (BS)

QUALIFIED VALVE

<u>VALVE SIZE:</u>	8"
<u>VALVE RATING CLASS:</u>	150
<u>DRAWING N°:</u>	N° N14200-DPL
<u>VALVE TYPE:</u>	SAT SIZE DN 8" FB CLASS 150
<u>MAX bar:</u>	15.9
<u>MAX °C:</u>	883

<u>RANGE AND TYPE OF</u>	NPS: 8" and larger (API6D) - DN: 200 and larger (API6FA)
<u>VALVES COVERED:</u>	NPS: 8" and larger DN: 200 and larger (ISO 10497 and API607)
	CLASS: 150; 300 (API6FA)
	CLASS: 150; 300 - PN 10; 16; 25; 40 (ISO 10497 and API607)

THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:

API SPECIFICATION 6FA Fifth Edition, January 2020

API STANDARD 607 Seventh Edition, June 2016

BS - UNI EN ISO 10497:2010

NOTES:

LOCATION AND DATE OF TEST CARRIED OUT:

At CO.MA.IS. s.a.s – Via Marelli, 70 – 20043 Cerro Maggiore (MI) - 01/12/2020

TÜV
INSPECTOR

