

Project:

Client: **PENTA srl - MOLINETTO (BS) - ITALY**

Office: **Milan**

Clients Order Number: **Fax dd. 22/09/2006**

Date: **20 November 2006**

Order Status: **Complete**

Inspection Dates

First: **17 November 2006**

Final: **17 November 2006**

This certificate is issued to **PENTA srl - MOLINETTO (BS) - ITALY**

To certify that Mr. G. RENIER Inspector to this Society did, at their request, attend their Works at Casorezzo (Milan) Italy, for the purpose of inspecting the Fire Safe Test according to API 607 Fifth Edition June 2005/EN 10497 Ed. Aug. 2004, on the following ball valve, manufactured, by PENTA S. R.L. - Molinetta (BS) - Italy:

DN 150 (6") ANSI 300# - CARBON STEEL METAL SEATED BALL VALVE TYPE SAT
TO DRAWING NO. F58800-DPL REV. A DATED 22/11/2004

The ball valve was tested in accordance with above specification

The test apparatus, test procedure and test results, as described in Fire Safe Test Report no. 0601, dated 17/11/2006, endorsed by the Undersigned, were found within the requirements of API 607 Fifth Edition June 2005/EN 10497 Ed. Aug. 2004,

The ball valve has passed the fire safe test.

G. RENIER
Inspector
Lloyd's Register EMEA
Milan Office of the Lloyd's Register Group

