



Italia

Certificato IS-272293-01-18
31/01/2018

Scegli la certezza.
Aggiungi valore.

FIRE SAFE TEST CERTIFICATE

Valve Type: **AP64 SOFT SEATED BALL VALVE SIZE DN 2" CLASS 150 RF**
To Drawing N° L92000-DPL rev.0
Date **nov-17**

CERTIFICATE NUMBER: IS-272293-01-18

CLIENT: PENTA S.r.l.
ADDRESS: VIA BOCCACCIO, 23
25080 MOLINETTO DI MAZZANO (BS)

REPORT NUMBER: N° 11/01/2018 L92000-DPL

SCOPE OF REPORT: Fire Safe test carried out according to Client procedure

BS - UNI EN ISO 10497:2010
API STANDARD 607 Seventh Edition, June 2016

max bar: 2,1

max °C: 832

TÜV
INSPECTOR

PAOLO POZZI



TÜV ITALIA S.R.L.
TÜV SÜD Group

Direzione e Sede Amministrativa:
Via Giosué Carducci, 125 edificio 23
20099 Sesto San Giovanni (MI)
Sede legale: Via Mauro Macchi, 27 20124 Milano
Società soggetta al controllo e al coordinamento di
TÜV SÜD AG

Telefono: +39 02 24130.1
Telefax: +39 02 24130.399

www.tuv.it

CERTIFICATION DATE

31/01/2018

MANAGEMENT OF
INSPECTION SERVICE

VITTORIO FEDERICI



Registro delle Imprese di Milano
n. iscrizione e Cod. Fisc. 08922920155
R.E.A. 1255140 - P. IVA 02055510966
Capitale sociale: Euro 500.000 int. vers.
Coord. Bancarie: INTESA BC1 - CIN J
c/c 000018978166 - ABI 03069 - CAB 32934
IBAN: IT34 J030 6932 9340 0001 8978 166

TÜV ITALIA S.R.L.
 TÜV SÜD Group
 Via Giosuè Carducci, 125 edificio 23
 20099 Sesto San Giovanni (MI)
 Telefono: +39 02 24130.1
 Telefax: +39 02 24130.399
 www.tuv.it



Italia

FIRE SAFE TECHNICAL REPORT	
<i>FIRE SAFE CERTIFICATE N°:</i> IS-272293-01-18	
<i>REPORT N°:</i> N° 11/01/2018 L92000-DPL	

<i>CLIENT:</i>	PENTA S.r.l.
<i>ADDRESS:</i>	VIA BOCCACCIO, 23 - 25080 MOLINETTO DI MAZZANO (BS)

QUALIFIED VALVE	
<i>VALVE SIZE:</i>	2"
<i>VALVE RATING CLASS:</i>	150
<i>DRAWING N°:</i>	N° L92000-DPL
<i>VALVE TYPE:</i>	AP64 SOFT SEATED BALL VALVE SIZE DN 2" CLASS 150 RF
<i>MAX bar:</i>	2,1
<i>MAX °C:</i>	832

<i>RANGE AND TYPE OF VALVES COVERED:</i>	NPS: 2 and below; 2 ½; 3; 4 DN: 50 and below; 65; 80; 100 (ISO 10497 and API607) CLASS: 150; 300 - PN 10; 16; 25; 40 (ISO 10497 and API607)
--	--

THE ABOVE MENTIONED VALVE SUCCESSFULLY PASSED THE FIRE SAFE IN ACCORDANCE TO:	
	API STANDARD 607 Seventh Edition, June 2016
	BS - UNI EN ISO 10497:2010

<i>NOTES:</i>	
<i>LOCATION AND DATE OF TEST CARRIED OUT:</i>	At CO.MA.IS. s.a.s – Via Marelli, 70 – 20043 Cerro Maggiore (MI) - 30/01/2018

TÜV
INSPECTOR

